



Pete K. Rahn, Director

**ADDENDUM 001
REQUEST FOR BID
D611-028-RW High Mast Tower Cable Repair**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original quote. The due date for receipt of this bid **does not change** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Terri Mount Sr. General Services Specialist
Bidder Signature	Department of Transportation <i>Terri Mount</i>
Signature of person authorized to sign	Authorizing Signature
Date Signed:	Date Signed: 8/31/10

Revision and Questions to Quotation:

REVISION: Page 1 First paragraph Second Sentence: Delete the sentence “ Contractor to provide 1 each luminaire power cable male plug and 1 each Power Cable Kellums Grip” **MoDOT will supply these items**

Question: Could you find out from lighting what is the brand of the lowering device in the Millerbernd tower and what year Sachs Electric installed these poles on the McCarthy project?

MoDOT Response: Upon physical inspection the lowering device is identified as a Millerbernd SSLD2- no other information available. MoDOT is still reviewing maps but no specific date has been identified; MoDOT personnel believe this specific tower was installed in the late 1970's.

THIS ADDENDUM MUST BE SIGNED AND SUBMITTED WITH RESPONSE.